

- NOTES:**
- DO NOT SCALE. USE FIGURED DIMENSIONS ONLY.
  - THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT ARCHITECTURAL AND ENGINEERING DRAWINGS.
  - ALL PIPE MATERIALS SHALL BE IN ACCORDANCE WITH SECTION 3.9 OF THE IRISH WATER CODE OF PRACTICE FOR WATER INFRASTRUCTURE. WATERMANS SHALL BE EITHER DUCTILE IRON (DI) OR POLYETHYLENE (PE), WITH PE80 OR PE100 RATING (MDPE, HDPEOR HPPE). ALL PLASTIC WATER PIPES SHALL BE BLUE IN COLOUR.
  - ALL SERVICE CONNECTIONS TO BE 25 $\phi$  HDPE(SDR-17).
  - ALL WATERMANS UNDER ROADS OR AT ROAD CROSSINGS TO BE HDPE OR DUCTILE IRON.
  - HDPE DISTRIBUTION PIPES TO BE PE-100(SDR-17).
  - DUCTILE IRON PIPES TO IS EN 545 WITH C40 POWER RATING.
  - AIR VALVE AND HYDRANTS COVERS, WHERE LOCATED IN GRASS AREAS, SHALL BE SURROUNDED BY A CONCRETE PLINTH, 200mm ALL ROUND AND 100mm DEEP FORMED WITH C20/25 CONCRETE, 20mm AGGREGATE SIZE, BEDDED IN CLAUSE 804 MATERIAL. THE PLINTH SHALL INCORPORATE MILD STEEL REINFORCED LINKS AND SHALL HAVE BULL-NOSE FINISH AROUND ITS EXTERNAL PERIMETER.
  - THRUST BLOCKS SHALL BE PROVIDED AT EACH BEND ALONG THE COURSE OF THE WATERMAIN.
  - PLANTING ADJACENT TO WATER INFRASTRUCTURE SHALL COMPLY WITH IRISH WATER STANDARD DETAIL STD-W-12A.
  - HORIZONTAL AND VERTICAL SERVICE LAYOUT DISTANCES SHALL BE AS PER IRISH WATER STANDARD DETAIL STD-W-11.
  - IT IS THE CONTRACTORS RESPONSIBILITY TO ENSURE THAT ALL WORKS ARE CONSTRUCTED IN ACCORDANCE WITH THE IRISH WATER CODE OF PRACTICE AND STANDARD DETAILS. THE CODE OF PRACTICE AND STANDARD DETAILS ARE AVAILABLE TO DOWNLOAD FROM THE IRISH WATER WEB SITE AT [WWW.WATER.IE/CONNECTIONS/DEVELOPER-SERVICES/](http://WWW.WATER.IE/CONNECTIONS/DEVELOPER-SERVICES/) WHERE THE DETAILS CONTAINED ON THIS DRAWING DIFFER FROM THE IRISH WATER CODE OF PRACTICE OR STANDARD DETAILS THIS MUST BE BROUGHT TO THE ATTENTION OF THE ENGINEER IMMEDIATELY. IRISH WATER STANDARDS WILL TAKE PRECEDENCE.

ion 10



**LEGEND:**

- XXXmm  $\phi$  PROPOSED 150 $\phi$  HDPE WATERMAIN WITH PIPE SIZE
- XXXmm  $\phi$  PROPOSED 100 $\phi$  HDPE WATERMAIN WITH PIPE SIZE
- XXXmm  $\phi$  EXISTING WATERMAIN WITH PIPE SIZE
- SV PROPOSED SLUICE VALVE
- ScV PROPOSED SCOUR VALVE
- H PROPOSED HYDRANT
- AV PROPOSED AIR VALVE
- M PROPOSED WATER METER
- BB PROPOSED BOUNDARY BOX AND CONNECTION

CONNECT TO TEMPORARY 'DEAD END' LAID IN PHASE 1 WORKS. REFER STD-W-05 FOR DETAILS.

PHASE 1 UNDER CONSTRUCTION

B	09/05/23	ISSUED FOR PLANNING	NS	MD
A	30/04/24	REVISED FOLLOWING COMMENTS RECEIVED FROM IRISH WATER	NS	SDN
Rev	Date	Description	By	CHK

**PROPOSED RESIDENTIAL DEVELOPMENT AT OLD SLANE ROAD, DROGHEDA, CO. LOUTH**

**PHASE 2 WATERMAIN LAYOUT AND LEVELS SHEET 2 OF 2**

Client: LAGAN HOMES TULLYALLEN LTD.



BLOCK 5, EASTPOINT BUSINESS PARK, ALFIE BYRNE ROAD, DUBLIN D03 H3F4 IRELAND. Tel: (01) 664 8900  
 Email: [info@waterman-moylan.ie](mailto:info@waterman-moylan.ie) [www.waterman-moylan.ie](http://www.waterman-moylan.ie)

<b>PLANNING</b>			
Designed By	NS	Approved	MD
Waterman Ref	23-067		
Drawn By	NS	Date	APRIL 2024
Scale	@ A1		
1:500			
Project	Originator	Volume	Level
OSR - WMC - ZZ - ZZ-DR - C - 3302			
Revision	B		